

[m3/h]		Ricambi Aria/Air Changes														
		[1/min]														
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Volume della Sala Prove/Volume of the Enclosure	20	1.200	2.400	3.600	4.800	6.000	7.200	8.400	9.600	10.800	12.000	13.200	14.400	15.600	16.800	18.000
	30	1.800	3.600	5.400	7.200	9.000	10.800	12.600	14.400	16.200	18.000	19.800	21.600	23.400	25.200	27.000
	40	2.400	4.800	7.200	9.600	12.000	14.400	16.800	19.200	21.600	24.000	26.400	28.800	31.200	33.600	36.000
	50	3.000	6.000	9.000	12.000	15.000	18.000	21.000	24.000	27.000	30.000	33.000	36.000	39.000	42.000	45.000
	60	3.600	7.200	10.800	14.400	18.000	21.600	25.200	28.800	32.400	36.000	39.600	43.200	46.800	50.400	54.000
	70	4.200	8.400	12.600	16.800	21.000	25.200	29.400	33.600	37.800	42.000	46.200	50.400	54.600	58.800	63.000
	80	4.800	9.600	14.400	19.200	24.000	28.800	33.600	38.400	43.200	48.000	52.800	57.600	62.400	67.200	72.000
	90	5.400	10.800	16.200	21.600	27.000	32.400	37.800	43.200	48.600	54.000	59.400	64.800	70.200	75.600	81.000
	100	6.000	12.000	18.000	24.000	30.000	36.000	42.000	48.000	54.000	60.000	66.000	72.000	78.000	84.000	90.000
	110	6.600	13.200	19.800	26.400	33.000	39.600	46.200	52.800	59.400	66.000	72.600	79.200	85.800	92.400	99.000
	120	7.200	14.400	21.600	28.800	36.000	43.200	50.400	57.600	64.800	72.000	79.200	86.400	93.600	100.800	108.000
	130	7.800	15.600	23.400	31.200	39.000	46.800	54.600	62.400	70.200	78.000	85.800	93.600	101.400	109.200	117.000
	140	8.400	16.800	25.200	33.600	42.000	50.400	58.800	67.200	75.600	84.000	92.400	100.800	109.200	117.600	126.000
	150	9.000	18.000	27.000	36.000	45.000	54.000	63.000	72.000	81.000	90.000	99.000	108.000	117.000	126.000	135.000
	160	9.600	19.200	28.800	38.400	48.000	57.600	67.200	76.800	86.400	96.000	105.600	115.200	124.800	134.400	144.000
	170	10.200	20.400	30.600	40.800	51.000	61.200	71.400	81.600	91.800	102.000	112.200	122.400	132.600	142.800	153.000
	180	10.800	21.600	32.400	43.200	54.000	64.800	75.600	86.400	97.200	108.000	118.800	129.600	140.400	151.200	162.000
	190	11.400	22.800	34.200	45.600	57.000	68.400	79.800	91.200	102.600	114.000	125.400	136.800	148.200	159.600	171.000
	200	12.000	24.000	36.000	48.000	60.000	72.000	84.000	96.000	108.000	120.000	132.000	144.000	156.000	168.000	180.000
	210	12.600	25.200	37.800	50.400	63.000	75.600	88.200	100.800	113.400	126.000	138.600	151.200	163.800	176.400	189.000
Necessità di ulteriori analisi/Need other analysis					Basse prestazioni/Low performance				Medie prestazioni/Medium performance				Alte prestazioni/High performance			

NOTA IMPORTANTE: le portate sopra esposte non sono esaustive ai fini della selezione del/i ventilatore/i da adottare per la realizzazione del ricambio d'aria in sala prove. La selezione del/i ventilatore/i da installare deve tener conto delle perdite di carico di condotte, silenziatori, griglie di diffusione e quant'altro costituisce la sala prove.

IMPORTANT NOTE: the flow rates shown above are not exhaustive for the purpose of selecting the fan/s to be used for carrying out the air exchange in the test room. The selection of the fan/s to be installed must take into account the load losses of the ducts, silencers, diffusion grilles and whatever else constitutes the test room.